

LOCATION 1302 INDUSTRIAL PIKE BLDG A CITY GASTON, NC  
BETWEEN BESSEMER CITY RD STREET & — STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>2"</u>	<u>CTW</u>	<u>80'</u>	<u>3-25-99</u>		
MAIN TO PROP LINE						
PROP LINE TO BLDG						

ENTERS 1302 BRANCHED INTO  
TAP SIZE 2" PRESSURE 60 PSI INCHES WC LOCATION 55' S OF

INDUSTRIAL PIKE  
PRESSURE TEST @ 100 PSI FOR 1 hr HRS BY M. Parker


SE MAIN SIZE 2" C I — BARE STEEL — COATED STEEL ✓ PLASTIC — YEAR INSTALLED —

DEPTH 1 FT 6 IN LOCATION 185' EAST OF BESSEMER CITY

RD

\*A\* P/S READING .95 TOTAL ANODES 1# — 17# — LR # —

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>.95</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	