


LOCATION 272 INYANNA D.V. CITY GASTONIA
 BETWEEN Old Byce STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	34'	Plastic	52'	5/14/99		
MAIN TO PROP LINE	34"		14'			
PROP LINE TO BLDG	34"		38'			

 ENTERS 272 BRANCHED INTO
 TAP SIZE 34' PRESSURE 60 PSI INCHES W.C. LOCATION S side of 272

PRESSURE TEST 100 PSI FOR 1/4 HRS BY DT
 MAIN SIZE 34' C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1999
 DEPTH 2 FT 0 IN LOCATION N side of 276

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 LR # 394093
 REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline lead Red	S	
New Service		
P/S Pipeline lead White	E	
Existing Main		