

LOCATION 503 Lexington Dr. CITY Winston

BETWEEN Lexington Dr STREET B STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>57'</u>	<u>2-17-99</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>53'</u>			

ENTERS: 503 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 P S I INCHES W.C. LOCATION 115' E. of center of Lexington Dr.


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs By S.H.

MAIN - SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1998

DEPTH: 3 Ft 0 In. LOCATION 16' N. of center of Groves Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 112723

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	