

LOCATION 1003 IRIS DR CITY Gastonia
VEEN ANDY STREET & RIVER STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
N TO BLDG	3/4	P	118'	7-20-99		
N TO PROP LINE	1"	1"	35'			
P LINE TO BLDG	1"	1"	73'			

ERS 1003 BRANCHED INTO
SIZE 1/2 PRESSURE _____ PSI _____ INCHES W/C LOCATION 17' S. of CH


SURE TEST @ 100 PSI FOR 1/4 HRS BY IRIS

N-SIZE 24 C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1971

TH 2 FT 6 IN LOCATION

P/S READING 1.20 TOTAL ANODES 1# 17# L.R. #

MARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	OR	P
P/S Pipeline Lead - White Existing Main	E	