

LOCATION 1006 IRIS DR CITY CASTORIA

BETWEEN Ginger DR. STREET & Andy LN. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>63'</u>	<u>7-30-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>53'</u>			

ENTERS: 1006 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI          INCHES W.C. LOCATION 211' W. OF center of

Ginger DR


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. Chubbuck

MAIN-SIZE 2" C.I.          BARE STEEL          COATED STEEL ✓ PLASTIC          YEAR INSTALLED         

DEPTH: 3 FT. 0 IN LOCATION 16' S. of center of IRIS DR

"A" P/S READING 1.3 TOTAL ANODES 1# 0 17# 0 L.R. # 539/63

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY