


LOCATION	1230 Ave 1230 Ave.				CITY	Easton	
BETWEEN	Belmont				STREET &	Bryant St	
	SIZE	TYPE	P	LENGTH S	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4		5	82	Turnover 7-30-94		
MAIN TO PROP. LINE	3/4		5	1			
PROP. LINE TO BLDG.	3/4		0	81			

ENTERS:	1230	BRANCHED INTO:	
TAP SIZE:	1/2	PRESSURE	_____ P.S.I. _____ INCHES W.C.
		LOCATION	W side of house

PRESSURE TEST:	@ 100 psi	For 1/4 Hrs.	By Barrett
MAIN-SIZE	2	C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC <input checked="" type="checkbox"/>	YEAR INSTALLED 1993
DEPTH:	2 Ft. 6 In.	LOCATION	19' N of C St

"A" P/S READING	0.20	TOTAL ANODES 1# 1 17# _____	L.R. # 325903
-----------------	------	-----------------------------	---------------

REMARKS:	
<div style="display: flex; justify-content: space-around;"> Bare Main Replacement Program Bare Main Replacement Program </div>	



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	.90
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY