

LOCATION 1614 Iverness Ct. CITY Gastonia
BETWEEN River Ridge Dr. STREET & Cul-de-Sac STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>73'</u>	<u>10-27-99</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>8'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>65'</u>			

ENTERS 1614 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W/C LOCATION 318" W of center of River Ridge Dr.

PRESSURE TEST @ 100 PSI FOR 44 HRS BY S.H.
MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1999
DEPTH 3 FT 0 IN LOCATION 40' N of center of Iverness Ct

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 922989

REMARKS.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>8</u>	
P/S Pipeline Lead White Existing Main	<u>8</u>	