

LOCATION 1621 FURNACE CT. CITY CANTON
BETWEEN River Ridge DR STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>1/2</u>	<u>P</u>	<u>113'</u>	<u>6-5-01</u>		
MAIN TO PROP LINE	<u>1/2</u>	<u>P</u>	<u>40'</u>			
PROP LINE TO BLDG	<u>1/2</u>	<u>P</u>	<u>73'</u>			

ENTERS 1621 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI INCHES WC LOCATION 220' W. of center
River Ridge DR


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 200

DEPTH 3 FT 0 IN LOCATION 17' N. of center of FURNACE CT

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # A0434729

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	