

LOCATION 1646 Iverness Ct. CITY GASTONIA  
BETWEEN Fox Borough Ct. STREET & River Ridge Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>PLASTIC</u>	<u>34'</u>	<u>6/27/00</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>4'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>PLASTIC</u>	<u>27'</u>			

ENTERS 1646 BRANCHED INTO 0  
TAP SIZE 3/4 PRESSURE 60 PSI INCHES W C LOCATION 100' N of C of Iverness Ct.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY R.L.

MAIN-SIZE 2" C I      BARE STEEL      COATED STEEL      PLASTIC ✓ YEAR INSTALLED 1999

DEPTH 3 FT 6 IN LOCATION 20' w of C of River Ridge Dr.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 LR #     

REMARKS



Test Station		
Reading & Location	Lead	Volts #
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>River</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>