

LOCATION 804 S. Jackson STCITY GASTBETWEEN Garrison BlvdSTREET & Eighth AV

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>102'</u>		<u>4-8-97</u>	
MAIN TO PROP. LINE	<u>" "</u>	<u>" "</u>	<u>48'</u>			
PROP. LINE TO BLDG.	<u>" "</u>	<u>" "</u>	<u>54'</u>			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: 3/4"PRESSURE 60 PSI _____ INCHES W.C.LOCATION 85' west from (C) of Garrison AvePRESSURE TEST @ 100 PSI FOR 1/4 HRS BY OPWMAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997DEPTH: FT 3 IN. 0 LOCATION WEST SIDE OF Jackson ST"A" P/S READING PTOTAL ANODES 1# - 17# -L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY