


LOCATION 808 S. JACKSON STCITY GASTBETWEEN GARRISON BLVDSTREET & EIGHTH AVE

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>45'</u>			
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>8'</u>			<u>4-9-97</u>
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>37'</u>			

ENTERS: SAMEBRANCHED INTO: 810 S. JACKSONTAP SIZE: 3/4"PRESSURE 60 PSI _____ INCHES W.C.LOCATION 101' EAST FROM (C) OF JACKSONPRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY gmSERVICE MAIN SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997DEPTH: 2 FT. IN LOCATION West Side of Jackson St."A" P/S READING PTOTAL ANODES 1# - 17# -L.R. # -

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY