

LOCATION 811 S JACKSON ST

CITY GAST

BETWEEN GARRISON

STREET & EIGHTH

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	62'			
MAIN TO PROP LINE	3/4	P	3'		4-9-97	
PROP. LINE TO BLDG.	3/4	P	59'			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE 3/4"

PRESSURE 60 PSI

INCHES W.C.

LOCATION 20' west from (C) OF JACKSON

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY Jpw

MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1997


DEPTH. 3 FT. IN LOCATION West Side of Jackson St

"A" P/S READING 7

TOTAL ANODES 1# - 17# -

L.R. # -

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY