

LOCATION 812 S JACKSON ST CITY GAST  
BETWEEN GARRISON STREET & EIGHTH AV STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>110'</u>			<u>4-10-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>47'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>63'</u>			

ENTERS: SAME BRANCHED INTO:  
TAP SIZE. 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 20' EAST FROM (C) OF JACKSON

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY Opw  
MAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997  
DEPTH: 3 FT 0 IN LOCATION West Side of Jackson St.

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY