

LOCATION 816 S JACKSON ST CITY GAST

BETWEEN EIGHTH STREET & GARRISON BLVD STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>98</u>		<u>4-10-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>47</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>51</u>			

ENTERS. SAME BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 20 west from (C) OF JACKSON


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY JPW

MAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT 0 IN LOCATION West Side of Jackson St.

"A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY