

LOCATION 824 S. JACKSON STCITY GASTBETWEEN EIGHTH AVSTREET & TENTH AV

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>94'</u>		<u>4-15-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>37'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>57</u>			

ENTERS: Same

BRANCHED INTO:

TAP SIZE: 3/4"PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C.LOCATION 19' WEST FROM (C) JACKSONPRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY gmrMAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC X YEAR INSTALLED 1997DEPTH: 3 FT 0 IN. LOCATION WEST SIDE OF JACKSON"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY