

LOCATION 840 S JACKSON ST CITY GAST

BETWEEN EIGHT STREET & TENTH STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>30</u>		<u>4-17-97</u>	
MAIN TO PROP. LINE	<u>1"</u>	<u>1"</u>	<u>18'</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>12'</u>			

ENTERS: SAME BRANCHED INTO: 842 S. JACKSON

TAP SIZE. 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 81' EAST from C of Jackson


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY AW

SERVICE MAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1997

DEPTH: 2 FT. 0 IN LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY