

LOCATION 1203 JACKSON ROAD CITY GASTONIA
BETWEEN JACKSON ST. STREET & YORK STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>85</u>		<u>12-05-97</u>	
MAIN TO PROP LINE	<u>"</u>	<u>"</u>	<u>6</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>79</u>			

ENTERS: BRANCHED INTO:
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 120' EAST OF JACKSON ST.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY NS
MAIN-SIZE 4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1997
DEPTH: 3 FT IN LOCATION 80' NORTH of JACKSON Rd.

"A" P/S READING _____ TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>P</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		