

LOCATION 1207 JACKSON ROAD CITY GASTONIA  
BETWEEN TWELFTH STREET & JACKSON ST. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>127</u>			
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>40</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>87</u>			

ENTERS: BRANCHED INTO:  
TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 295' East of Twelfth

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY NS  
MAIN-SIZE 4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC X YEAR INSTALLED 1991  
DEPTH: 3 FT IN. LOCATION \_\_\_\_\_

"A" P/S READING \_\_\_\_\_ TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: Tied over 87' 3/4" PLASTIC  
40' NEW 3/4" PLASTIC



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY