

LOCATION 1210 JACKSON ROAD CITY GASTONIA
BETWEEN JACKSON ROAD STREET & JACKSON ST. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>39</u>		<u>12-08-97</u>	
MAIN TO PROP. LINE	<u>1/1</u>	<u>1/1</u>	<u>4</u>			
PROP. LINE TO BLDG.	<u>1/1</u>	<u>1/1</u>	<u>35</u>			

ENTERS: _____ BRANCHED INTO: _____
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 96' NORTH of JACKSON ROAD

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY NS
MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1997
DEPTH: 3 FT IN LOCATION 12' west of JACKSON ST.

"A" P/S READING _____ TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>XR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY