

LOCATION 1212 JACKSON RD CITY GASTONIA

BETWEEN TWELFTH STREET & JACKSON ST. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>64</u>		<u>12-10-97</u>	
MAIN TO PROP. LINE	<u>1"</u>	<u>1"</u>	<u>2</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>62</u>			

ENTERS: BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 334' EAST OF TWELFTH


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY NS

MAIN-SIZE 4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC X YEAR INSTALLED 1997

DEPTH 3 FT IN LOCATION 22' NORTH OF JACKSON RD

"A" P/S READING \_\_\_\_\_ TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>XR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY