

LOCATION 1214 JACKSON ROADCITY GASTONIABETWEEN TwelfthSTREET & JACKSON ST.

STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|-----------|-----------|-----------|-----------------|---------|
| MAIN TO BLDG. | <u>3/4</u> | <u>P</u> | <u>90</u> | | <u>12/08/97</u> | |
| MAIN TO PROP. LINE | <u>11</u> | <u>11</u> | <u>3</u> | | | |
| PROP. LINE TO BLDG. | <u>11</u> | <u>11</u> | <u>87</u> | | | |

ENTERS:

BRANCHED INTO:

| | | | |
|----------------------|------------------------|------------|--------------------------------------|
| TAP SIZE: <u>3/4</u> | PRESSURE <u>60</u> PSI | INCHES W.C | LOCATION <u>175' EAST OF TWELFTH</u> |
|----------------------|------------------------|------------|--------------------------------------|


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY NS

| | | | | | |
|--------------------|------------|------------------|--------------------|------------------|----------------------------|
| MAIN-SIZE <u>4</u> | C.I. _____ | BARE STEEL _____ | COATED STEEL _____ | PLASTIC <u>X</u> | YEAR INSTALLED <u>1997</u> |
|--------------------|------------|------------------|--------------------|------------------|----------------------------|

DEPTH: 3 FT IN LOCATION 23' NORTH OF JACKSON ROAD

| | | |
|-----------------------|---------------------------------|--------------|
| "A" P/S READING _____ | TOTAL ANODES 1# _____ 17# _____ | L.R. # _____ |
|-----------------------|---------------------------------|--------------|

REMARKS:



| Test Station | | |
|--|-----------|----------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>SR</u> | <u>P</u> |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT. USE ONLY