

LOCATION 1220 JACKSON RD CITY GASTONIA
BETWEEN 12TH STREET & JACKSON ST. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>76</u>			<u>12-17-97</u>
MAIN TO PROP LINE	<u>"</u>	<u>"</u>	<u>2</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>74</u>			

ENTERS: BRANCHED INTO:
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 134' EAST of 12TH

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY NS
MAIN-SIZE 4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1997
DEPTH: 3 FT IN. LOCATION 22' NORTH of JACKSON ROAD

"A" P/S READING _____ TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Tied over 76' of existing 3/4" PLASTIC service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY