

LOCATION 1231 JACKSON RD CITY GASTONIA

BETWEEN 12TH STREET & JACKSON ST, STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>143</u>		<u>12-18</u>	<u>-97</u>
MAIN TO PROP. LINE	<u>1"</u>	<u>1"</u>	<u>44</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>99</u>			

ENTERS: BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI INCHES W C LOCATION 90' EAST of 12TH


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY NS

MAIN-SIZE 4 C.I. BARE STEEL COATED STEEL PLASTIC X YEAR INSTALLED 1997

DEPTH: 3 FT IN. LOCATION 28' NORTH OF JACKSON RD

"A" P/S READING TOTAL ANODES 1# 17# L.R. #

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY