

LOCATION 1307 & 1307 1/2 JACKSON ROAD CITY GASTONIA

BETWEEN Home TRAIL STREET & Hillcrest Av. STREET

	SIZE	TYPE	1307 LENGTH 1307 1/2	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>122</u> . . . <u>151</u>			<u>01-12-98</u>
MAIN TO PROP. LINE	<u>1"</u>	<u>1"</u>	<u>44</u> . . . <u>0</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>78</u> . . . <u>151</u>			

ENTERS. 1307 JACKSON ROAD BRANCHED INTO: 1307 1/2 JACKSON ROAD

TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 22' N of JACKSON RD

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY NS

MAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC X YEAR INSTALLED 1997

DEPTH 4 FT. IN. LOCATION 62' west of Home TRAIL

"A" P/S READING \_\_\_\_\_ TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>P</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		