

LOCATION 1324 A+B JACKSON ROADCITY GASTONIABETWEEN HILLCRESTSTREET & HOMER TRAIL


STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>328</u>		<u>01-20-98</u>	
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>5</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>323</u>			

ENTERS: 1324ABRANCHED INTO: 1324BTAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W/C LOCATION 256' EAST OF HILLCRESTPRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY N.S.MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1997DEPTH: 4 FT. IN. LOCATION 22' NORTH OF JACKSON ROAD

"A" P/S READING _____ TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>PR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY