

LOCATION 1612 Jackson Rd CITY Cast.

BETWEEN Townsend STREET & Carolina Ave. STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|-------------|-----------|------------------|-----------|-----------|--------------|
| MAIN TO BLDG. | <u>3/4"</u> | <u>P.</u> | <u>Ø TIEOVER</u> | | <u>1-</u> | <u>18-98</u> |
| MAIN TO PROP. LINE | <u>"</u> | <u>"</u> | | | | |
| PROP. LINE TO BLDG. | <u>"</u> | <u>"</u> | | | | |

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 215' from @ OF

Townsend

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY D.F.

MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN LOCATION W. OF Jackson Rd

"A" P/S READING P. TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:

Tie
OVERS

| Test Station | | | ENG. DEPT. USE ONLY | |
|--|----------|-------|---------------------|--|
| Reading & Location | Lead | Volts | | |
| P/S Pipeline Lead - Red New Service | <u>S</u> | | | |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | | | |

