

LOCATION 2646 JACOBS RD CITY GASTON  
 BETWEEN SHAW STREET & DEND END STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>142'</u>	<u>5-12-99</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>50</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>92</u>			

ENTERS: 2646 BRANCHED INTO

TAP SIZE: 3/8 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 80' E OF  
SHAW


PRESSURE TEST @ 100 PSI FOR 4 HRS BY M. Parker

MAIN SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ✓ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1972

DEPTH 3 FT 0 IN LOCATION 23' S OF JACOBS

"A" P/S READING .6 TOTAL ANODES 1# \_\_\_\_\_ 17# 1 LR # \_\_\_\_\_

REMARKS  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	
P/S Pipeline Lead White Existing Main	<u>E</u>	