

LOCATION 107 Jake Long Rd CITY Gastonia
BETWEEN Chapel Grove Rd. STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>183'</u>			<u>11-12-96</u>
MAIN TO PROP. LINE ^{Ext 3/4 c/w}	<u>3/4</u>	<u>P</u>	<u>30'</u>	<u>underground</u>		
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>153'</u>			

ENTERS: 107 BRANCHED INTO:
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ 105 PSI FOR 1 1/4 HRS. BY LEP
MAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED _____
DEPTH: 2 FT. 0 IN. LOCATION _____

"A" P/S READING 1.3 TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS:
Tracer wire bonded to Ext 3/4 c/w stub



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY