

LOCATION 4400 Jance Dr CITY GASTONIA

BETWEEN LISA DR. STREET & DOACI ENCL. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>34"</u>	<u>P</u>	<u>110'</u>	<u>3-12-99</u>		
MAIN TO PROP LINE	<u>34"</u>	<u>P</u>	<u>40'</u>			
PROP LINE TO BLDG	<u>34"</u>	<u>P</u>	<u>30'</u>			

ENTERS 4908 BRANCHED INTO

TAP SIZE 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 128' S. of center of LISA DR

PRESSURE TEST @ 100 PSI FOR 44 HRS BY S.H.

MAIN SIZE 2" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED

DEPTH 3 FT 0 IN LOCATION 17' E. of center of Jance Dr

A P/S READING 1.3 TOTAL ANODES 1# 0 17# 0 LR # 165783

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	
P/S Pipeline Lead White Existing Main	<u>E</u>	

