

LOCATION 3060 Jamestown Dr. CITY Eastonia  
BETWEEN Robinwood Rd. STREET & Dare Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>125'</u>	<u>11-8-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>44'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>81'</u>			

ENTERS: 3060 BRANCHED INTO: 0

TAP SIZE: 3/8 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 40' S of Dare Ct.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1981

DEPTH: 3 Ft. 0 In. LOCATION 17' W of E of Jamestown Dr.

"A" P/S READING 1.0 TOTAL ANODES 1\* \_\_\_\_\_ 17\* 1 L.R. # 533333

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY