

LOCATION 516 JASIN CITY Easton
 BETWEEN: _____ STREET & _____ STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|-------------------|------------|----------|------------|------------------|-----------------|---------|
| MAIN TO BLDG | <u>3/4</u> | <u>P</u> | <u>78'</u> | <u>Relocated</u> | <u>10-18-99</u> | |
| MAIN TO PROP LINE | | | | | | |
| PROP LINE TO BLDG | | | | | | |

ENTERS 516 BRANCHED INTO 0
 TAP SIZE 3/4 IN. PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY EP
 SIZE 3/4 C I _____ RARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED _____
 DEPTH 2 FT 6 IN LOCATION _____

"A" P/S READING 1.3 TOTAL ANODES 1# — 17# — LR # _____

REMARKS
Tracer wire bonded to Riser 3/4 900 Ser.
Use Tracer Wire At Riser for Test point

