

LOCATION 615 JASIN Dr. CITY Castroville

BETWEEN Gardner Park Dr. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>21'</u>	<u>Relocated</u>	<u>10-28-98</u>	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 615 BRANCHED INTO 623

TAP SIZE: 3/4 in. PRESSURE 600 PSI INCHES W C LOCATION


PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY EP

MAIN-SIZE 3/4 C.I. BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED

DEPTH 3 FT 0 IN LOCATION

"A" P/S READING 1.1 TOTAL ANODES 1# 17# L.R. #

REMARKS:
Tracer wire bonded to EFT New Service.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY