

LOCATION 1301 W. Jay St. CITY GASTONIA
BETWEEN JAY St. STREET & RANKIN St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>53'</u>	<u>1-24-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>31'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>22'</u>			

ENTERS: 1301 BRANCHED INTO: 0

TAP SIZE: 3/8 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 84' S of Jay St.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By AL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1962

DEPTH: 2 Ft. 0 In. LOCATION 15' E of Scruggs St.

"A" P/S READING .80 TOTAL ANODES 1# 17# 1 L.R. # 013344

REMARKS: new 3/4 Plastic Gas Service with A Road Bore.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline, Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY