

LOCATION 2040 Jefferson Ave CITY GASTONIA
BETWEEN ROSE GARDEN STREET & CUL-DE-SAC STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>123'</u>	<u>6-30-99</u>		
MAIN TO PROP LINE	<u>"</u>	<u>"</u>	<u>47'</u>			
PROP LINE TO BLDG	<u>"</u>	<u>"</u>	<u>76</u>			

ENTERS SAME BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES WC LOCATION 19' South of Jefferson
310' East of Rose Garden

PRESSURE TEST @ 100 PSI FOR 4 HRS BY M.D.

MAIN SIZE 2" CI BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1986

DEPTH 3'-0" IN LOCATION South Side of Jefferson

"A" P/S READING P TOTAL ANODES 1# — T# — LR # —

REMARKS

Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	
P/S Pipeline Lead White Existing Main	<u>E</u>	

