

LOCATION 2051 Jefferson Ave. CITY GASTONIA  
BETWEEN Rose Garden Dr. STREET & Caldwells AC STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>77'</u>	<u>5-2-03</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>4'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>73'</u>	<u>"</u>		

ENTERS 2051 BRANCHED INTO D  
TAP SIZE 3/4" PRESSURE 60 PSI INCHES WC LOCATION 306' East


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody center of Rose Garden

MAIN SIZE 2" C I        BARE STEEL        COATED STEEL        PLASTIC        YEAR INSTALLED 1987

DEPTH 3' FT 0" IN LOCATION 22' south of center of Jefferson Ave.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # CC11006

REMARKS New Plastic Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Plastic
P/S Pipeline Lead - White Existing Main	E	Risen