

LOCATION 1900 1/2 Jenkins Dairy Rd.

CITY GASTONIA

BETWEEN Mt. Olive Church Rd.

STREET &amp; Jenkins Dairy Rd.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	180'	11-14-95		
MAIN TO PROP. LINE	3/4	Plastic	20'			
PROP. LINE TO BLDG.	3/4	Plastic	160'			

ENTERS: 1900 1/2

BRANCHED INTO: 0

TAP SIZE: 3/8

PRESSURE 60 P.S.I.

INCHES W.C.

LOCATION 979' W of C of Jenkins Dairy Rd.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED 1980

DEPTH: 4 Ft. 0 In. LOCATION 14' S of C of Mt. Olive Church Rd.

"A" P/S READING 60 TOTAL ANODES 1# 17# 1 L.R. # 560930

REMARKS: Metal Track Wash Building Behind Western Auto Ware House.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY