

LOCATION 412 Jenny St. CITY GASTONIA  
BETWEEN, Melvin STREET & Mullinax STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>120'</u>	<u>10-29-97</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>80'</u>			

ENTERS: 412 BRANCHED INTO: 0  
TAP SIZE: 1/2 PRESSURE 600 PSI \_\_\_\_\_ INCHES W.C. LOCATION 136' S of C of Melvin Dr.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1993  
DEPTH: 3 FT. 6 IN. LOCATION 15' W of C of Jenny St.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 241349

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY