

LOCATION 434 Jenny St. CITY CASTONIA
 BETWEEN Melvin St. STREET & WILLIMAX Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>28'</u>	<u>8-17-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>13'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>15'</u>			

ENTERS: 444 Jenny St. BRANCHED INTO: 434 Jenny St.
 TAP SIZE: 3/4 Straight Plastic Tee PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 130' N of C of WILLIMAX Ave.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

SERVICE MAIN SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1995

DEPTH: 2 Ft. 0 In. LOCATION 86' E of C of Jenny St.

"A" P/S READING Plastic N/A TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Split Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY