


LOCATION <u>444 Jenny St</u>		CITY <u>GASTONIA</u>				
BETWEEN <u>William Ave.</u>		STREET & <u>McLure St</u>			STREET	
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>100'</u>	<u>8-9-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>30'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>70'</u>			

ENTERS: <u>444</u>		BRANCHED INTO:	
TAP SIZE: <u>1/2</u>	PRESSURE <u>60</u> P.S.I.	INCHES W.C.	LOCATION <u>121' N. of center of William Ave.</u>

PRESSURE TEST: @ <u>100</u> psi For <u>1/4</u> Hrs. By <u>S. HUFFSTADT</u>			
MAIN-SIZE <u>2"</u>	C.I. <u> </u>	BARE STEEL <u> </u>	COATED STEEL <u> </u> PLASTIC <input checked="" type="checkbox"/> YEAR INSTALLED <u>1995</u>
DEPTH: <u>3</u> Ft. <u>0</u> In.		LOCATION <u>10' W. of center of Jenny St</u>	

"A" P/S READING <u>7</u>	TOTAL ANODES 1# <u>0</u> 17# <u>0</u>	L.R. # <u>383536</u>
--------------------------	---------------------------------------	----------------------

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY