


LOCATION 527 John Ln.CITY CastrovilleBETWEEN WoodSTREET & Perry

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>3'</u>	<u>Tied over 22' of EXT</u> <u>3/4 plastic to EXT 4"</u> <u>plastic main</u> <u>3-21-98</u>		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 527BRANCHED INTO: 0TAP SIZE: 1/2 PRESSURE 600 PSI _____ INCHES W.C. LOCATION _____PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY EDMAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1998DEPTH: 3 FT. 6 IN. LOCATION _____"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY