

LOCATION 702 Johns Ln CITY Casteria
BETWEEN Perry STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>104'</u>			<u>8</u>
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>40'</u>			<u>4/4/98</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>64'</u>			


ENTERS: 702 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY ED
MAIN-SIZE 24 C.I.: _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1998

DEPTH: 3 FT. 0 IN. LOCATION _____

"A" P/S READING P TOTAL ANODES 1# 17# L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>PLEASE</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY