

LOCATION 125 John Freeman LnCITY GASTONIABETWEEN AirportSTREET & —

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>98</u>	<u>9-21-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>				
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>				

ENTERS: 125

BRANCHED INTO:

TAP SIZE: 1/2 (PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 11' S OFPrivate DrivePRESSURE TEST: @ 100 psi For 4 Hrs. By M. ParkerMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1994DEPTH: 3 Ft. 0 In. LOCATION 493' W OF John Freeman Ln"A" P/S READING P TOTAL ANODES 1* _____ 17* _____ L.R. # 415718

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P-RISEK</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY