

LOCATION 126 John Freeman LNCITY GASTONIA

BETWEEN

Airport Rd.

STREET &

—

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>180'</u>	<u>9-21-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>				
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>				

ENTERS: 126

BRANCHED INTO: —

TAP SIZE: 1/2PRESSURE 60 P.S.I.


INCHES W.C.

LOCATION 11' Southof Private DrivePRESSURE TEST: @ 100 psi For 1/4 Hrs. By M ParkerMAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC / YEAR INSTALLED 1994DEPTH: 3 Ft. 0 In.LOCATION 492' W of John Freeman LN"A" P/S READING P

TOTAL ANODES 1* — 17* —

L.R. # 415728

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P-riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY