

LOCATION 1204 Jones St CITY GASTONIA
BETWEEN Hometraic STREET & JACKSON STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Plastic</u>	<u>28'</u>	<u>8/22/97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>		<u>20'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>		<u>50'</u>			

ENTERS: 1204 BRANCHED INTO:
TAP SIZE: 3/8" PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DR

MAIN-SIZE 3/4" C.I. _____ BARE STEEL ☒ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED P-30

DEPTH: 2 FT. 6 IN. LOCATION _____

"A" P/S READING 50 TOTAL ANODES 1# 1 17# 0 L.R. # 0

REMARKS: _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY