

LOCATION 1206 Jones St CITY Antonia
BETWEEN Home Trl. STREET & Jackson St STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>96'</u>			<u>✓</u>
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>56'</u>			<u>1-10-98</u>

ENTERS: 1206 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 600 PSI _____ INCHES W.C. LOCATION

PRESSURE TEST: @ 100 PSI FOR 44 HRS. BY EP
MAIN-SIZE 2 1/2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997
DEPTH: 3 FT. 6 IN. LOCATION

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY