

LOCATION 1217 Jones St. CITY Castoria

BETWEEN Jackson St. STREET & Home Trail STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>51'</u>			<u>1-10-98</u>
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>46'</u>			

ENTERS: 1217 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 278' E. of center of

Home Trail


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Hufford

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION 13' S. of center of Jones St.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY