


LOCATION 3610 Jordanview LN. CITY GASTOWIABETWEEN Bryant Cole way STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>110'</u>	<u>3-4-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>70'</u>			

ENTERS: 3610 BRANCHED INTO: 0TAP SIZE: 1/2 PRESSURE 600 PSI INCHES W.C. LOCATION 96' N of (of) Bryant Cole wayPRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY BLMAIN-SIZE 2" C.I.      BARE STEEL      COATED STEEL      PLASTIC ✓ YEAR INSTALLED 1992DEPTH: 3 FT. 0 IN. LOCATION 18' W of (of) Jordanview LN."A" P/S READING PLASTIC N/A TOTAL ANODES 1# 0 17# 0 L.R. # 086649

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser PLASTIC</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY