

LOCATION 3611 Jordanview Lane CITY GASTONIA
BETWEEN BryantCoke way STREET & BryantCoke way STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>55'</u>	<u>9-13-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>50'</u>			

ENTERS: 3611 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 118' N of Cap BryantCoke way


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By AL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1992

DEPTH: 3 Ft. 0 In. LOCATION 19' W of Cap Jordanview Lane

"A" P/S READING Plastic TOTAL ANODES 1* 17* L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY