


LOCATION 3624 Jordanview LN.CITY GASTONIABETWEEN Bryant Cole WAYSTREET & Bryant Cole WAY

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>136'</u>	<u>8-23-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>46'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>110'</u>			

ENTERS: 3624BRANCHED INTO: 0TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 221' N of C of Bryant Cole WAYPRESSURE TEST: @ 100 psi For 1/4 Hrs. By ALMAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1992DEPTH: 3 Ft. 0 In. LOCATION 21' W of C of Jordanview LN."A" P/S READING Plastic TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_REMARKS: New 3/4 Plastic Service, with Road Bore.

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY