


LOCATION 926 Jupiter stCITY GastoniaBETWEEN CrescentSTREET & Dead end

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	99	4-7-95		
MAIN TO PROP. LINE	11	"	33			
PROP. LINE TO BLDG.	11	"	66			

ENTERS: 926BRANCHED INTO: 0TAP SIZE: 1/2PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C.LOCATION 332' N of C of  
Crescent lanePRESSURE TEST: @ 100 psi For 1/4 Hrs. By BCMAIN-SIZE 2 1/2 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1995DEPTH: 3 Ft. \_\_\_\_\_ In. LOCATION 14' W of C of Jupiter"A" P/S READING plastic TOTAL ANODES 1# - 17# - L.R. # 457671

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY